



# 1 EU-TYPE EXAMINATION CERTIFICATE

- 2 Equipment intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU
- 3 Certificate Number: Sira 09ATEX2040X
- 4 Equipment: FT151 2-Wire Optic Overfill Sensor
- 5 Applicant: Dixon Bayco
- 6 Address: 7280 Union Centre Boulevard West Chester OH 45014 United States of America
- 7 This equipment and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

Issue:

8

8 CSA Group Netherlands B.V., notified body number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 60079-0:2018

EN 60079-11:2012

- 10 If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to Specific Conditions of Use identified in the schedule to this certificate.
- 11 This EU-Type Examination Certificate relates only to the design and construction of the specified equipment. If applicable, further requirements of this Directive apply to the manufacture and supply of this equipment.
- 12 The marking of the equipment shall include the following:

II 1G Ex ia IIB T4 Ga; Ta =  $-40^{\circ}$ C to  $+70^{\circ}$ C

Project Number 80011217

Signed: J A May

Title: Director of Operations

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V. Utrechtseweg 310, 6812 AR, Arnhem, Netherlands

Page 1 of 4



i.



## SCHEDULE

# EU-TYPE EXAMINATION CERTIFICATE

Sira 09ATEX2040X Issue 8

#### 13 DESCRIPTION OF EQUIPMENT

The FT151 2-Wire Optic Overfill Sensor provides overfill control for mobile and permanently mounted liquid storage vessels. The FT151 enclosure is cast aluminum with a 2" NPT mounting thread, heavy-duty stainless steel sections, and Viton<sup>®</sup> seals. The sensor is installed in a 2 inch NPT tapped hole or 2-3/8 inch hole using the gasket and locking nut provided. The sensor contains a single PCB contained within a fully potted cavity and has 2 permanently connected wires.

The safety description for the sensor is:

Ui = 13.7 V Ii = 180 mA Pi = 1 W  $Ci = 0 \mu F$   $Li = 2 \mu H$ 

Variation 1 - This variation introduced the following changes:

- A number of changes to various drawings including:
  - Part number 10006 changed to 10006D.
  - Leaded resistor R6 added (18kΩ).
  - R15 changed from  $10\Omega$  to  $39\Omega$ .
  - Change of label material.
  - Addition of some informative text. This text does not affect compliance with the applied standards.
  - A change to a thread dimension on the sensor housing.
- ii. The Applicant's address was changed from 4740T Interstate Drive, Cincinnati, Ohio, 45246, USA to that shown on page 1.

Variation 2 - This variation introduced the following changes:

- i. The introduction of three models based upon cable length 24 inch, 48 inch, and 60 inch the latter terminated with a plug.
- ii. The encapsulant has now been fully specified.
- iii. The marking was amended to include Li which has changed from 0 mH to 2  $\mu$ H, this was recognised in the product description.

Variation 3 - This variation introduced the following changes:

- i. The corporate logo was added to the label.
- ii. An increase in the sensor tube lengths from 7" to 12" and 18" was approved.

Variation 4 - This variation introduced the following changes:

 It was recognised that the manufacturer can now supply the user with a new overfill sensor unit that will replace the one in the FT151 5-Wire Overfill Sensor Probe already in their possession. The new sensor unit is designated as equipment name FT150, its construction is the same as the existing sensor unit and it bears an explanatory label that clearly states that it is part of an FT151, Sira 09ATEX2040X.

Variation 5 - This variation introduced the following change:

i. The plastic spacer was removed.

Variation 6 - This variation introduced the following change:

This certificate and its schedules may only be	CSA Group Netherlands B.V.
reproduced in its entirety and without change	Utrechtseweg 310,
	6812 AR, Arnhem Netherlands





# SCHEDULE

# EU-TYPE EXAMINATION CERTIFICATE

Sira 09ATEX2040X Issue 8

- i. Drawing Number 10183 has been updated from revision G to revision H, to recognize changing the type of holes from bolt holes to thru holes in the sensor housing.
- ii. The following assessment has been conducted appropriately to demonstrate compliance with the latest technical knowledge, where EN 60079-0:2006 and EN 60079-11:2007 had been replaced by EN 60079-0:2018 and EN 60079-11:2012.
- iii. The product input current value has been added to the certificate.
- iv. EN 60079-26:2007 and the reference to IEC 60079-0:2007 (used for guidance in respect of marking) had been removed from the certificate. Superseded with the latest versions of the relevant applicable standards.
- v. The Product Name has been amended from FT151 2-Wire Overfill Sensor Probe to FT151 2-Wire Optic Overfill Sensor. The product description has been updated accordingly.
- vi. Conditions of Manufacturer had been removed from the affected certificate (Sira 09ATEX2040X) and highlighted in report R80011217A section 1.11.
- vii. The manufacturer's address has been updated.

#### 14 DESCRIPTIVE DOCUMENTS

#### 14.1 Drawings

Refer to Certificate Annexe.

# 14.2 Associated Sira Reports and Certificate History

Issue	Date	Report number	Comment
0	20 July 2009	R52A16755D	The release of the prime certificate.
1	21 April 2011	R52A16755D/01	Re issued to allow report R52A16755D/01 to replace
			R52A16755D
2	19 August 2011	R23939A/00	The introduction of Variation 1.
3	18 September 2014	R70005584A	The introduction of Variation 2.
4	27 April 2015	R70024621A	The introduction of Variation 3.
5	07 September 2015	R70041681A	The introduction of Variation 4.
6	07 February 2017	R70113728A	This Issue covers the following changes:
			EC Type-Examination Certificate in accordance
			with 94/9/EC updated to EU Type-Examination
			Certificate in accordance with Directive
			2014/34/EU. (In accordance with Article 41 of Directive
			2014/34/EU, EC Type-Examination Certificates referring to
			94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were
			issued in accordance with Directive 2014/34/EU. Variations to
			such EC Type-Examination Certificates may continue to bear the
			original certificate number issued prior to 20 April 2016.)
			The introduction of Variation 5.
7	15 October 2019	1018	Transfer of certificate Sira 09ATEX2040X from Sira
			Certification Service to CSA Group Netherlands B.V
8	20 February 2020	R80011217A	The introduction of Variation 6.

This certificate and its schedules may only be reproduced in its entirety and without change **CSA Group Netherlands B.V.** Utrechtseweg 310, 6812 AR, Arnhem Netherlands





## SCHEDULE

#### EU-TYPE EXAMINATION CERTIFICATE

Sira 09ATEX2040X Issue 8

- 15 **SPECIFIC CONDITIONS OF USE** (denoted by X after the certificate number)
- 15.1 As aluminium is used at the accessible surface of this equipment ignition sources due to impact and friction sparks could occur in the event of rare incidents. This shall be considered when the FT151 Sensor is being installed, particularly in locations that specifically require Group II, Category 1G equipment.
- 15.2 The assessed enclosure should not be subjected to strong impact that may lead to high risk of mechanical danger.

#### 16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

**CSA Group Netherlands B.V.** Utrechtseweg 310, 6812 AR, Arnhem Netherlands

# **Certificate Annexe**



Certificate Number:	Sira 09ATEX2040X
Equipment:	FT151 2-Wire Optic Overfill Sensor
Applicant:	Dixon Bayco

## Issue 0

Drawing No.:	Sheets	Rev.	Date: (Sira Stamp)	Description
10000	1 of 1	В	17 Mar 09	ASSY, Optic Head
10085_ATEX	1 of 1	Α	17 Mar 09	PCB Assembly Thermo-optic Sensor
10109-ATEX	1 of 1	А	17 Mar 09	ASSY, 2 Wire Sensor
10183	1 of 1	D	17 Mar 09	Sensor Housing (Machining)
10185	1 of 1	Α	17 Mar 09	Sensor Housing Cap (Machining)
10245_ATEX	1 of 1	Α	17 Mar 09	Sensor, Two-wire Thermo-optic Sensor
10246_ATEX	1 of 1	А	17 Mar 09	PCB, Two-wire Thermo-optic Sensor
10585	1 of 1	В	17 Mar 09	ATEX Marking – FT151

Issue 1 - No new drawings were introduced.

#### Issue 2

Drawing No	Sheets	Rev.	Date (Sira stamp)	Title
10000	1 of 1	D	18 Aug 11	Assy, Optic Head
10085_ATEX	1 of 1	E	18 Aug 11	PCB Assembly Thermo Optic Sensor
10183	1 of 1	G	18 Aug 11	Sensor housing – sand cast (machining)
10185	1 of 1	В	18 Aug 11	Sensor housing cap (machining)
10245_ATEX	1 of 1	D	18 Aug 11	Sensor, two wire thermo-optic sensor
10585	1 of 1	С	18 Aug 11	Label, Thermo Optic Sensor

#### Issue 3

Drawing	Sheets	Rev.	Date (Sira stamp)	Title
10085-48_ATEX	1 of 1	А	25 Jul 14	FT151 OVERFILL SENSOR PCB ASSEMBLY
10085-PP_ATEX	1 of 1	А	25 Jul 14	FT151 OVERFILL SENSOR P/P, PCB ASSEMBLY
10619_ATEX	1 of 1	E	25 Jul 14	PROBE PLUG - 2 WIRE
10109_ATEX	1 of 1	В	28 Jul 14	ASSY, 2 WIRE SENSOR
10109-PP_ATEX	1 of 1	Α	29 Aug 14	ASSY, SENSOR 2 WIRE
10585	1 of 1	D	27 Aug 14	Label, Thermo Optic Sensor FT151 Type

#### Issue 4

Drawing	Sheets	Rev.	Date (Sira stamp)	Title
10109-PP-7-AX	1 of 1	А	02 Apr 15	ASSY, SENSOR 2 WIRE
10109-PP-12-AX	1 of 1	Α	02 Apr 15	ASSY, SENSOR 2 WIRE
10109-PP-18-AX	1 of 1	А	02 Apr 15	ASSY, SENSOR 2 WIRE
10585	1 of 1	E	02 Apr 15	LABEL, OVERFILL SENSOR FT151 TYPE
FT151PB-ATEX-7	1 of 1	Α	02 Apr 15	PLUG & PLAN THERMO-OPTIC SENSOR (BSPP THD)
FT151PB-ATEX-12	1 of 1	А	02 Apr 15	PLUG & PLAN THERMO-OPTIC SENSOR (BSPP THD)
FT151PB-ATEX-18	1 of 1	А	02 Apr 15	PLUG & PLAN THERMO-OPTIC SENSOR (BSPP THD)

#### Issue 5

Drawing no.	Sheets	Rev.	Date (Sira stamp)	Description
1058X-001	1 of 1	А	18 Aug 15	Label, replacement overfill sensor

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V. Utrechtseweg 310, 6812 AR, Arnhem, Netherlands

# **Certificate Annexe**



Certificate Number:	Sira 09ATEX2040X
Equipment:	FT151 2-Wire Optic Overfill Sensor
Applicant:	Dixon Bayco

Issue 6

Drawing	Sheets	Rev.	Date (Sira stamp)	Title
FT151PB-ATEX-12	1 of 1	С	30 Jan 17	PLUG & PLAN THERMO-OPTIC SENSOR (BSPP THD)
FT151PB-ATEX-18	1 of 1	С	30 Jan 17	PLUG & PLAN THERMO-OPTIC SENSOR (BSPP THD)

Issue 7 - No new drawings were introduced.

#### Issue 8

Drawing	Sheets	Rev.	Date (Date stamp)	Title
10183	1 of 1	Н	28 Jan 20	Sensor Housing - Sand Cast (Machining)
10585	1 of 1	Н	28 Jan 20	Label, Overfill Sensor FT151 Type
10588	1 to 2	27 Jan 20	28 Jan 20	Instruction Manual 10588 ATEX Supplemental
				Instruction Sheet For Sensors FT150 and FT151

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V. Utrechtseweg 310, 6812 AR, Arnhem, Netherlands